

Copy of the Fire Safety Certificate approved by Chief Fire Officer, Ahmedabad Municipal Corporation



afes@ahmedabadcity.gov.in



FORM B 13.3 FIRE SAFETY CERTIFICATE RENEWAL (FSCR) (See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOAMC/2023/00038629

Date: 14/10/2026

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOAMC/2023/00038629/R1

Building Occupancy/Category: Educational (non-residential)

To,

Sonalben Hingu
UNITED VALLEY INTERNATIONAL SCHOOL FP 45/2, NEAR SOMNATH NAGAR VASTRAL ROAD RTO ROAD AHMEDABAD
FP 45/2, NEAR SOMNATH NAGAR VASTRAL ROAD RTO ROAD AHMEDABAD AHMEDABAD Ahmedabad MC 382418
Fire Region: Ahmedabad MC
Mobile No: 9979975127 Email ID: hingujig@yahoo.com

We have received Application No. 2026/00232416 dated 26/09/2026 for Fire Safety Certificate Renewal (FSCR) - New Building(FSCR)/Existing Building (FSCRe) for the building/premise UNITED VALLEY INTERNATIONAL SCHOOL (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: AHMEDABAD
5. Name of Block(s): 1

The building/premise was inspected on 14/10/2026 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 28/09/2026 3:53:30 PM
2. Six monthly inspection was done on 29/09/2026 5:12:19 PM

The Fire Safety Certificate is renewed for a period of two (2) years upto 16/10/2028 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated: 14/10/2026 7:07:38 PM



Digitally Verified

Digitally verified by: Jitlal Babulal Sharma
Fire Safety Officer - Specialist (FSO-S)
2021/000801
Reviewed by : CFO Ahmedabad MC
Date: 14/10/2026
Time: 07:39 PM



FSCA/O/CFOAMC/2023/00038629/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.


PRINCIPAL
UNITED VALLEY INTERNATIONAL SCHOOL
NEAR SOMNATHNAGAR, R.T.O. ROAD,
VASTRAL, AHMEDABAD-382418.